

Attachment L - Results Summary Lead in Water Samples

School Name: Hillsborough Elementary School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
HES-1-16-CF	HES-30-1118-01	Sink faucet; Room 16	9.65	No
HES-1-1A-CF	HES-30-1118-02	Sink faucet; Room 1A	55.2	Yes
HES-1-15-SB	HES-30-1118-03	Bubbler on sink; Room 15	ND	No
HES-1-15-CF	HES-30-1118-04	Sink faucet; Room 15	ND	No
HES-1-2-CF	HES-30-1118-05	Sink faucet; Room 2	27.6	Yes
HES-1-14-SB	HES-30-1118-06	Bubbler on sink; Room 14	1.19	No
HES-1-14-CF	HES-30-1118-07	Sink faucet; Room 14	ND	No
HES-1-3-SB	HES-30-1118-08	Bubbler on sink; Room 3	ND	No
HES-1-3-CF	HES-30-1118-09	Sink faucet; Room 3	1.21	No
HES-1-13-SB	HES-30-1118-10	Bubbler on sink; Room 13	ND	No
HES-1-13-CF	HES-30-1118-11	Sink faucet; Room 13	1.37	No
HES-1-4-SB	HES-30-1118-12	Bubbler on sink; Room 4	ND	No
HES-1-4-CF	HES-30-1118-13	Sink faucet; Room 4	1.2	No
HES-1-12-SB	HES-30-1118-14	Bubbler on sink; Room 12	1.52	No
HES-1-12-CF	HES-30-1118-15	Sink faucet; Room 12	1.11	No
HES-1-11-SB	HES-30-1118-16	Bubbler on sink; Room 11	1.31	No
HES-1-11-CF	HES-30-1118-17	Sink faucet; Room 11	2.2	No
HES-1-5-SB	HES-30-1118-18	Bubbler on sink; Room 5	1.11	No
HES-1-5-CF	HES-30-1118-19	Sink faucet; Room 5	2.73	No
HES-1-10-SB	HES-30-1118-20	Bubbler on sink; Room 10	1.74	No

Action Level (AL) ≥ 15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported

Attachment L - Results Summary Lead in Water Samples

School Name: Hillsborough Elementary School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
HES-1-10-CF	HES-30-1118-21	Sink faucet; Room 10	3.29	No
HES-1-6-SB	HES-30-1118-22	Bubbler on sink; Room 6	2.17	No
HES-1-6-CF	HES-30-1118-23	Sink faucet; Room 6	2.21	No
HES-1-8-CF	HES-30-1118-24	Sink faucet; Room 8	4.83	No
HES-1-H7-DW	HES-30-1118-25	WF; hallway at Room 7	9.92	No
HES-1-7-CF	HES-30-1118-26	Sink faucet; Room 7	1.59	No
HES-1-H9A-DW	HES-30-1118-27	WF; hallway at Room 9A	4.02	No
HES-1-HLIB-WC1	HES-30-1118-28	WF; across Library; lower unit	ND	No
HES-1-HLIB-WC2	HES-30-1118-29	WF; across Library; upper unit	ND	No
HES-1-LIBRARY-TF	HES-30-1118-30	Sink faucet; Library Office	4.7	No
HES-1-KITCHEN-FP	HES-30-1118-31	Sink faucet; Kitchen; Food Prep	3.74	No
HES-1-TR-TF	HES-30-1118-32	Sink faucet; Teachers Room	5.66	No
HES-1-TR-WC	HES-30-1118-33	Water Cooler; Teachers Room	ND	No
HES-1-NURSE-NS1	HES-30-1118-34	Sink faucet; Nurse Office; main area	ND	No
HES-1-NURSE-NS2	HES-30-1118-35	Sink faucet; Nurse Office; exam room	2.88	No
HES-1-MO-TF	HES-30-1118-36	Sink faucet; Main Office kitchenette	ND	No
HES-1-ENTRANCE-DW	HES-30-1118-37	WF; hallway at Main Entrance	1.77	No
HES-1-101-CF	HES-30-1118-38	Sink faucet; Room 101	43.6	Yes
HES-1-HGYM-DW	HES-30-1118-39	WF; hallway at CST	4.23	No
HES-1-CST-CF	HES-30-1118-40	Sink faucet; CST office	19.3	Yes

Action Level (AL) ≥ 15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported

Attachment L - Results Summary Lead in Water Samples

School Name: Hillsborough Elementary School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
HES-1-H114-DW	HES-30-1118-41	WF; hallway at Room 114	9.38	No
HES-1-ART-CF1	HES-30-1118-42	Sink faucet; Room ART	1.8	No
HES-1-102-CF	HES-30-1118-43	Sink faucet; Room 102	20.4	Yes
HES-1-103-CF	HES-30-1118-44	Sink faucet; Room 103	9.84	No
HES-1-113-CF	HES-30-1118-45	Sink faucet; Room 113	24.4	Yes
HES-1-104-CF	HES-30-1118-46	Sink faucet; Room 104	4.01	No
HES-1-105-SB	HES-30-1118-47	WF; Room 105	3.01	No
HES-1-105-CF	HES-30-1118-48	Sink faucet; Room 105	5.52	No
HES-1-112-CF	HES-30-1118-49	Sink faucet; Room 112	60.6	Yes
HES-1-106-DW	HES-30-1118-50	WF; Room 106	4.73	No
HES-1-106-CF	HES-30-1118-51	Sink faucet; Room 106	2.71	No
HES-1-111-CF	HES-30-1118-52	Sink faucet; Room 111	3.86	No
HES-1-107-CF	HES-30-1118-53	Sink faucet; Room 107	8.91	No
HES-1-110-CF	HES-30-1118-54	Sink faucet; Room 110	3.38	No
HES-1-108-CF	HES-30-1118-55	Sink faucet; Room 108	7.22	No
HES-1-109-SB	HES-30-1118-56	WF; Room 109	3.84	No
HES-1-109-CF	HES-30-1118-57	Sink faucet; Room 109	2.02	No
QC BLANK	HES-30-1118-58	DI Blank	ND	No

Action Level (AL) ≥ 15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported