



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

---

Attn:

**Tom Pruno**  
**Environmental Design, Inc.**  
**5434 King Avenue**  
**Suite 101**  
**Pennsauken, NJ 08109**

12/18/2017

Phone: (856) 616-9516  
Fax: (586) 616-9517

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/4/2017. The results are tabulated on the attached data pages for the following client designated project:

**HTPS - Hillsborough Middle School - PR-171031-1172**

The reference number for these samples is EMSL Order #011709642. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Phillip Worby, Environmental Chemistry  
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011709642

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**  
**Environmental Design, Inc.**  
**5434 King Avenue**  
**Suite 101**  
**Pennsauken, NJ 08109**

Phone: (856) 616-9516  
 Fax: (586) 616-9517  
 Received: 12/04/17 3:30 PM

Project: **HPS - Hillsborough Middle School - PR-171031-1172****Analytical Results**

**Client Sample Description** HMS-1201-01  
 HMS-1-NURSE-WC; WF; Nurse Office  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.60	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-02  
 HMS-1-NURSE-NS1; Sink Faucet; Nurse Office  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.76	1.00	µg/L	12/13/2017	TD	12/13/2017	JW

**Client Sample Description** HMS-1201-03  
 HMS-1-NEXAM-NS2; Sink Faucet; Nurse Exam Room  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-04  
 HMS-1-MO-TF; Sink Faucet; Main Office Kitchenette  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.51	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-05  
 HMS-1-MO-CF; Sink Faucet; Main Office Conf.  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-06  
 HMS-1-MO-TF; Sink Faucet; Main Office Bathroom  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-07  
 HMS-1-HMEDIA-WC; WF; Hallway by Media Center  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011709642  
 CustomerID: EDI50  
 CustomerPO:  
 ProjectID:

Attn: **Tom Pruno**  
**Environmental Design, Inc.**  
**5434 King Avenue**  
**Suite 101**  
**Pennsauken, NJ 08109**

Phone: (856) 616-9516  
 Fax: (586) 616-9517  
 Received: 12/04/17 3:30 PM

Project: **HPS - Hillsborough Middle School - PR-171031-1172**

**Analytical Results**

**Client Sample Description** HMS-1201-08  
 HMS-1-A15-CF; Sink Faucet; Room A15  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.61	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-09  
 HMS-1-MC-TF; Sink Faucet; Media Center Office  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.23	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-10  
 HMS-1-HB3-DW1; WF; Hallway Across From Room B3  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-11  
 HMS-1-HB3-DW2; WF; Hallway Across From Room B3  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.09	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-12  
 HMS-1-HB3-DW3; WF; Hallway Across From Room B3  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.08	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-13  
 HMS-1-HB3-DW4; WF; Hallway Across From Room B3  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.20	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-14  
 HMS-1-C7-IM; IM; Prep Room in Rom C7  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011709642

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**  
**Environmental Design, Inc.**  
**5434 King Avenue**  
**Suite 101**  
**Pennsauken, NJ 08109**

Phone: (856) 616-9516  
 Fax: (586) 616-9517  
 Received: 12/04/17 3:30 PM

Project: **HPS - Hillsborough Middle School - PR-171031-1172****Analytical Results**

**Client Sample Description** HMS-1201-15  
 HMS-1-FACS1-CF; Sink Faucet; Room FACS1  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	12.7	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-16  
 HMS-1-FACS2-CF1; Sink Faucet; Room FACS2  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.42	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-17  
 HMS-1-FACS2-CF2; Sink Faucet; Room FACS2  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.50	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-18  
 HMS-1-FACS2-CF3; Sink Faucet; Room FACS2  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0018

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.89	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-19  
 HMS-1-FACS2-CF4; Sink Faucet; Room FACS2  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-20  
 HMS-1-B5-IM; IM; Prep Room in Room B5  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-21  
 HMS-1-HKIT-DW2; WF; Hallway Across from Kitchen  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.51	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011709642  
 CustomerID: EDI50  
 CustomerPO:  
 ProjectID:

Attn: **Tom Pruno**  
**Environmental Design, Inc.**  
**5434 King Avenue**  
**Suite 101**  
**Pennsauken, NJ 08109**

Phone: (856) 616-9516  
 Fax: (586) 616-9517  
 Received: 12/04/17 3:30 PM

Project: **HPS - Hillsborough Middle School - PR-171031-1172**

**Analytical Results**

**Client Sample Description** HMS-1201-22  
 HMS-1-HKIT-DW3; WF; Hallway Across from Kitchen  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.87	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-23  
 HMS-1-KITCHEN-FP1; Sink Faucet; Kitchen; Food Prep  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0023

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.30	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-24  
 HMS-1-KITCHEN-FP2; Sink Faucet; Kitchen; Food Prep  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0024

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.05	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-25  
 HMS-1-KITCHEN-FP3; Sink Faucet; Kitchen; Food Prep  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0025

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.87	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-26  
 HMS-1-KITCHEN-KT; Sink Faucet; Kitchen; Kettle  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0026

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-27  
 HMS-1-CAF-WC; WF; In Cafeteria  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0027

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-28  
 HMS-1-FACULTY-TF; Sink Faucet; Faculty Dining  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0028

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.25	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011709642  
 CustomerID: EDI50  
 CustomerPO:  
 ProjectID:

Attn: **Tom Pruno**  
**Environmental Design, Inc.**  
**5434 King Avenue**  
**Suite 101**  
**Pennsauken, NJ 08109**

Phone: (856) 616-9516  
 Fax: (586) 616-9517  
 Received: 12/04/17 3:30 PM

Project: **HTPS - Hillsborough Middle School - PR-171031-1172**

**Analytical Results**

**Client Sample Description** HMS-1201-29  
 HMS-1-HGLR-DW2; WF; Hallway at Girls Locker Room  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0029

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.17	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-30  
 HMS-1-GLR OFFICE-BRS; Sink Faucet; Girls Locker Room Office  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0030

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.97	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-31  
 HMS-1-GLR-BRS1; Sink Faucet; Girls Locker Room  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0031

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.38	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-32  
 HMS-1-GLR-BRS1; Sink Faucet; Girls Locker Room  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0032

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.28	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-33  
 HMS-1-HBLR-DW1; WF; Hallway at Boys Locker Room  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0033

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.72	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-34  
 HMS-1-HBLR-DW2; WF; Hallway at Boys Locker Room  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0034

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.98	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-35  
 HMS-1-BLR OFFICE-BRS; Sink Faucet; Boys Locker Room Office  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0035

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.12	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011709642

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**  
**Environmental Design, Inc.**  
**5434 King Avenue**  
**Suite 101**  
**Pennsauken, NJ 08109**

Phone: (856) 616-9516  
 Fax: (586) 616-9517  
 Received: 12/04/17 3:30 PM

Project: **HPS - Hillsborough Middle School - PR-171031-1172****Analytical Results**

**Client Sample Description** HMS-1201-36  
 HMS-1-BLR-BRS1; Sink Faucet; Boys Locker Room  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0036

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.34	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-37  
 HMS-1-BLR-BRS2; Sink Faucet; Boys Locker Room  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0037

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.34	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-38  
 HMS-1-HB14-DW1; WF; Hallway by Room B14  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0038

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.03	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-39  
 HMS-1-HB14-DW3; WF; Hallway by Room B14  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0039

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.23	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-40  
 HMS-1-A9-IM; IM; Prep Room in Room A9  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0040

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-41  
 HMS-1-HANNEX-WC1; WF; Hallway Behind Stage  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0041

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-42  
 HMS-1-HANNEX-WC2; WF; Hallway Behind Stage  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0042

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011709642  
 CustomerID: EDI50  
 CustomerPO:  
 ProjectID:

Attn: **Tom Pruno**  
**Environmental Design, Inc.**  
**5434 King Avenue**  
**Suite 101**  
**Pennsauken, NJ 08109**

Phone: (856) 616-9516  
 Fax: (586) 616-9517  
 Received: 12/04/17 3:30 PM

Project: **HTPS - Hillsborough Middle School - PR-171031-1172**

**Analytical Results**

**Client Sample Description** HMS-1201-43  
 HMS-1-BAND ROOM2-IM; IM; Band Office  
 (Old Annex Kitchen) **Collected:** 12/1/2017 **Lab ID:** 011709642-0043

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-44  
 HMS-1-H22-WC1; WF; Hallway by Room 22 **Collected:** 12/1/2017 **Lab ID:** 011709642-0044

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-45  
 HMS-1-H22-WC2; WF; Hallway by Room 22 **Collected:** 12/1/2017 **Lab ID:** 011709642-0045

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.54	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-46  
 HMS-1-HE23-CF1; Sink Faucet; Room HE23 **Collected:** 12/1/2017 **Lab ID:** 011709642-0046

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.38	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-47  
 HMS-1-HE23-CF2; Sink Faucet; Room HE23 **Collected:** 12/1/2017 **Lab ID:** 011709642-0047

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.97	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-48  
 HMS-1-HE23-CF3; Sink Faucet; Room HE23 **Collected:** 12/1/2017 **Lab ID:** 011709642-0048

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-49  
 HMS-1-HE23-CF4; Sink Faucet; Room HE23 **Collected:** 12/1/2017 **Lab ID:** 011709642-0049

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011709642  
 CustomerID: EDI50  
 CustomerPO:  
 ProjectID:

Attn: **Tom Pruno**  
**Environmental Design, Inc.**  
**5434 King Avenue**  
**Suite 101**  
**Pennsauken, NJ 08109**

Phone: (856) 616-9516  
 Fax: (586) 616-9517  
 Received: 12/04/17 3:30 PM

Project: **HTPS - Hillsborough Middle School - PR-171031-1172**

**Analytical Results**

**Client Sample Description** HMS-1201-50  
 HMS-1-D14-IM; IM; Prep Room in Room D14  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0050

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-51  
 HMS-1-D11-CF; Sink Faucet; Room D11  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0051

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.09	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-52  
 HMS-1-H10-WC1; WF; Hallway by Room D10  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0052

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-53  
 HMS-1-H10-WC2; WF; Hallway by Room D10  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0053

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-54  
 HMS-1-HD4-WC1; WF; Hallway Across from Room D4  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0054

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-55  
 HMS-1-HD4-WC2; WF; Hallway Across from Room D4  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0055

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-56  
 HMS-1-D4-SB; Bubbler on Sink; Room D4  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0056

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011709642

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**  
**Environmental Design, Inc.**  
**5434 King Avenue**  
**Suite 101**  
**Pennsauken, NJ 08109**

Phone: (856) 616-9516  
 Fax: (586) 616-9517  
 Received: 12/04/17 3:30 PM

Project: **HTPS - Hillsborough Middle School - PR-171031-1172****Analytical Results**

**Client Sample Description** HMS-1201-57  
 HMS-1-D4-CF; Sink Faucet; Room D4  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0057

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.35	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-58  
 HMS-1-GUIDANCE-TF; Sink Faucet; Guidance  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0058

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.15	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-59  
 HMS-1-D22-SB; Bubbler on Sink; Room D22  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0059

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Client Sample Description** HMS-1201-60  
 HMS-1-D22-CF; Sink Faucet; Room D22  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0060

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/11/2017	SM	12/11/2017	SM

**Client Sample Description** HMS-1201-61  
 HMS-1-OUTDOOR-HB; Hose Bib Outside by Cust. Office  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0061

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/13/2017	TD	12/13/2017	JW

**Client Sample Description** HMS-1201-62  
 QC Blank; DI Blank  
**Collected:** 12/1/2017 **Lab ID:** 011709642-0062

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	12/8/2017	SM	12/8/2017	SM

**Definitions:**

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)