

## Attachment L - Results Summary Lead in Water Sample

School Name: Hillsborough Middle School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
HMS-1-NURSE-WC	HMS-1201-01	WF; Nurse Office	1.6	No
HMS-1-NURSE-NS1	HMS-1201-02	Sink faucet; Nurse Office	6.76	No
HMS-1-NEXAM-NS2	HMS-1201-03	Sink faucet; Nurse Exam Room	ND	No
HMS-1-MO-TF	HMS-1201-04	Sink faucet; Main Office kitchenette	2.51	No
HMS-1-MO-CF	HMS-1201-05	Sink faucet; Main Office conf.	ND	No
HMS-1-MOBR-BRS	HMS-1201-06	Sink faucet; Main Office bathroom	ND	No
HMS-1-HMEDIA-WC	HMS-1201-07	WF; hallway by Media Center	ND	No
HMS-1-A15-CF	HMS-1201-08	Sink faucet; Room A15	1.61	No
HMS-1-MC-TF	HMS-1201-09	Sink faucet; Media Center office	5.23	No
HMS-1-HB3-DW1	HMS-1201-10	WF; hallway across from Room B3	ND	No
HMS-1-HB3-DW2	HMS-1201-11	WF; hallway across from Room B3	2.09	No
HMS-1-HB3-DW3	HMS-1201-12	WF; hallway across from Room B3	3.08	No
HMS-1-HB3-DW4	HMS-1201-13	WF; hallway across from Room B3	3.2	No
HMS-1-C7-IM	HMS-1201-14	IM; Prep Room in Room C7	ND	No
HMS-1-FACS1-CF	HMS-1201-15	Sink faucet; Room FACS1	12.7	No
HMS-1-FACS2-CF1	HMS-1201-16	Sink faucet; Room FACS2	1.42	No
HMS-1-FACS2-CF2	HMS-1201-17	Sink faucet; Room FACS2	1.5	No
HMS-1-FACS2-CF3	HMS-1201-18	Sink faucet; Room FACS2	1.89	No
HMS-1-FACS2-CF4	HMS-1201-19	Sink faucet; Room FACS2	ND	No
HMS-1-B5-IM	HMS-1201-20	IM; Prep Room in Room B5	ND	No

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)  
 ND = None Detected; NR = Not Reported

## Attachment L - Results Summary Lead in Water Sample

School Name: Hillsborough Middle School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
HMS-1-HKIT-DW2	HMS-1201-21	WF; hallway across from Kitchen	1.51	No
HMS-1-HKIT-DW3	HMS-1201-22	WF; hallway across from Kitchen	3.87	No
HMS-1-KITCHEN-FP1	HMS-1201-23	Sink faucet; Kitchen; Food Prep	1.3	No
HMS-1-KITCHEN-FP2	HMS-1201-24	Sink faucet; Kitchen; Food Prep	3.05	No
HMS-1-KITCHEN-FP3	HMS-1201-25	Sink faucet; Kitchen; Food Prep	2.87	No
HMS-1-KITCHEN-KT	HMS-1201-26	Sink faucet; Kitchen; Kettle	ND	No
HMS-1-CAF-WC	HMS-1201-27	WF; in cafeteria	ND	No
HMS-1-FACULTY-TF	HMS-1201-28	Sink faucet; Faculty Dining	1.25	No
HMS-1-HGLR-DW2	HMS-1201-29	WF; hallway at Girls Locker Room	6.17	No
HMS-1-GLR OFFICE-BRS	HMS-1201-30	Sink faucet; Girls Locker Room Office	1.97	No
HMS-1-GLR-BRS1	HMS-1201-31	Sink faucet; Girls Locker Room	1.38	No
HMS-1-GLR-BRS1	HMS-1201-32	Sink faucet; Girls Locker Room	1.28	No
HMS-1-HBLR-DW1	HMS-1201-33	WF; hallway at Boys Locker Room	7.72	No
HMS-1-HBLR-DW2	HMS-1201-34	WF; hallway at Boys Locker Room	1.98	No
HMS-1-BLR OFFICE-BRS	HMS-1201-35	Sink faucet; Boys Locker Room Office	8.12	No
HMS-1-BLR-BRS1	HMS-1201-36	Sink faucet; Boys Locker Room	1.34	No
HMS-1-BLR-BRS2	HMS-1201-37	Sink faucet; Boys Locker Room	2.34	No
HMS-1-HB14-DW1	HMS-1201-38	WF; hallway by Room B14	4.03	No
HMS-1-HB14-DW3	HMS-1201-39	WF; hallway by Room B14	4.23	No
HMS-1-A9-IM	HMS-1201-40	IM; Prep Room in Room A9	ND	No

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)  
 ND = None Detected; NR = Not Reported

## Attachment L - Results Summary Lead in Water Sample

School Name: Hillsborough Middle School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
HMS-1-HANNEX-WC1	HMS-1201-41	WF; hallway behind Stage	ND	No
HMS-1-HANNEX-WC2	HMS-1201-42	WF; hallway behind Stage	ND	No
HMS-1-BAND ROOM2-IM	HMS-1201-43	IM; Band Office (old Annex kitchen)	ND	No
HMS-1-H22-WC1	HMS-1201-44	WF; hallway by Room 22	ND	No
HMS-1-H22-WC2	HMS-1201-45	WF; hallway by Room 22	3.54	No
HMS-1-HE23-CF1	HMS-1201-46	Sink faucet; Room HE23	1.38	No
HMS-1-HE23-CF2	HMS-1201-47	Sink faucet; Room HE23	4.97	No
HMS-1-HE23-CF3	HMS-1201-48	Sink faucet; Room HE23	ND	No
HMS-1-HE23-CF4	HMS-1201-49	Sink faucet; Room HE23	ND	No
HMS-1-D14-IM	HMS-1201-50	IM; Prep Room in Room D14	ND	No
HMS-1-D11-CF	HMS-1201-51	Sink faucet; Room D11	5.09	No
HMS-1-HD10-WC1	HMS-1201-52	WF; hallway by Room D10	ND	No
HMS-1-HD10-WC2	HMS-1201-53	WF; hallway by Room D10	ND	No
HMS-1-HD4-WC1	HMS-1201-54	WF; hallway across from Room D4	ND	No
HMS-1-HD4-WC2	HMS-1201-55	WF; hallway across from Room D4	ND	No
HMS-1-D4-SB	HMS-1201-56	Bubbler on sink; Room D4	ND	No
HMS-1-D4-CF	HMS-1201-57	Sink faucet; Room D4	8.35	No
HMS-1-GUIDANCE-TF	HMS-1201-58	Sink faucet; Guidance	1.15	No
HMS-1-D22-SB	HMS-1201-59	Bubbler on sink; Room D22	ND	No
HMS-1-D22-CF	HMS-1201-60	Sink faucet; Room D22	ND	No

Action Level (AL)  $\geq 15.5$  parts per billion (ppb)  
 ND = None Detected; NR = Not Reported

