

Attachment L - Results Summary Lead in Water Samples

School Name: Woodfern Elementary School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
WES-1-MOWR-TF	WES-30-1118-01	Sink faucet; Main Office work room	10.3	No
WES-1-110-SB	WES-30-1118-02	Bubbler on sink; Room 110	1.58	No
WES-1-110-CF	WES-30-1118-03	Sink faucet Room 110	2.15	No
WES-1-NURSE-NS1	WES-30-1118-04	Sink faucet; Nurse Office main area	6.14	No
WES-1-NURSE-NS2	WES-30-1118-05	Sink faucet; Nurse Exam Room	4.70	No
WES-1-109-SB	WES-30-1118-06	Bubbler on sink; Room 109	1.72	No
WES-1-109-CF	WES-30-1118-07	Sink faucet Room 109	3.39	No
WES-1-107A-SB	WES-30-1118-08	Bubbler on sink; Room 107A	2.50	No
WES-1-107A-CF	WES-30-1118-09	Sink faucet Room 107A	2.90	No
WES-1-102-SB	WES-30-1118-10	Bubbler on sink; Room 102	ND	No
WES-1-102-CF	WES-30-1118-11	Sink faucet Room 102	2.24	No
WES-1-103-SB	WES-30-1118-12	Bubbler on sink; Room 103	1.42	No
WES-1-103-CF	WES-30-1118-13	Sink faucet Room 103	2.43	No
WES-1-107-SB	WES-30-1118-14	Bubbler on sink; Room 107	2.48	No
WES-1-107-CF	WES-30-1118-15	Sink faucet Room 107	3.77	No
WES-1-104-SB	WES-30-1118-16	Bubbler on sink; Room 104	1.82	No
WES-1-104-CF	WES-30-1118-17	Sink faucet Room 104	2.56	No
WES-1-106-SB	WES-30-1118-18	Bubbler on sink; Room 106	4.44	No
WES-1-106-CF	WES-30-1118-19	Sink faucet Room 106	5.20	No
WES-1-105-SB	WES-30-1118-20	Bubbler on sink; Room 105	1.81	No

Action Level (AL) ≥15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported

Attachment L - Results Summary Lead in Water Samples

School Name: Woodfern Elementary School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
WES-1-105-CF	WES-30-1118-21	Sink faucet Room 105	2.91	No
WES-1-LIBRARY-TF	WES-30-1118-22	Sink faucet; Library office	2.54	No
WES-1-111-SB	WES-30-1118-23	Bubbler on sink; Room 111	61.4	Yes
WES-1-111-CF	WES-30-1118-24	Sink faucet Room 111	7.53	No
WES-1-GUIDANCE-TF	WES-30-1118-25	Sink faucet; Speech Room next to Rm 120	1.07	No
WES-1-112-CF	WES-30-1118-26	Sink faucet; Room 112	6.09	No
WES-1-120-CF	WES-30-1118-27	Sink faucet; Room 120	7.46	No
WES-1-119-SB	WES-30-1118-28	Bubbler on sink; Room 119	8.48	No
WES-1-119-CF	WES-30-1118-29	Sink faucet; Room 119	5.55	No
WES-1-113-CF	WES-30-1118-30	Sink faucet; Room 113	4.61	No
WES-1-118-CF	WES-30-1118-31	Sink faucet; Room 118	9.42	No
WES-1-114-SB	WES-30-1118-32	Bubbler on sink; Room 114	10.5	No
WES-1-114-CF	WES-30-1118-33	Sink faucet Room 114	5.96	No
WES-1-117-CF	WES-30-1118-34	Sink faucet; Room 117	6.05	No
WES-1-115-CF	WES-30-1118-35	Sink faucet; Room 115	10.5	No
WES-1-116-SB	WES-30-1118-36	Bubbler on sink; Room 116	58.3	Yes
WES-1-116-CF	WES-30-1118-37	Sink faucet Room 116	5.68	No
WES-1-KITCHEN-FP	WES-30-1118-38	Sink faucet; Kitchen; Food Prep	1.69	No
WES-1-FACULTY-LOUNGE-TF	WES-30-1118-39	Sink faucet; Faculty Lounge	1.76	No
WES-1-121-SB	WES-30-1118-40	Bubbler on sink; Room 121	ND	No

Action Level (AL) ≥ 15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported

Attachment L - Results Summary Lead in Water Samples

School Name: Woodfern Elementary School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
WES-1-121-CF	WES-30-1118-41	Sink faucet Room 121	5.18	No
WES-1-122-SB	WES-30-1118-42	Bubbler on sink; Room 122	ND	No
WES-1-122-CF	WES-30-1118-43	Sink faucet Room 122	6.17	No
WES-1-123-SB	WES-30-1118-44	Bubbler on sink; Room 123	ND	No
WES-1-123-CF	WES-30-1118-45	Sink faucet Room 123	4.58	No
QC BLANK	WES-30-1118-46	DI Blank	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)
ND = None Detected; NR = Not Reported