Attachment L - Results Summary Lead in Water Sample

School Name: Auten Road Intermediate School *(12-21-17 data, only)*

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
ARIS-1-HCAF-WC1	ARIS-1221-01	WF; hallway between cafe & gym (Left)	ND	No
ARIS-1-HCAF-WC2	ARIS-1221-02	WF; hallway between cafe & gym (Right)	ND	No
ARIS-2-223-SB	ARIS-1221-03	Bubbler on sink; Room 223	ND	No
ARIS-2-223-CF	ARIS-1221-04	Sink faucet; Room 223	ND	No
QC BLANK	ARIS-1221-05	DI Blank	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)
ND = None Detected; NR = Not Reported