

Field_ID	Flushed_Y/N	Laboratory_Sample_ID	Laboratory_Name	Lab_Certification_ID	Date_Sampled	Time_Sampled	Analytical_Method	Date_of_Analysis	Time_of_Analysis	Concentration_in_ug/L	Reporting_Limit_ug/L	Dilution_Factor	Digested_Y	Qualifier
Field Blank	N	2224670001	ALS	NJ PA010	4/20/2017	5:00	EPA 200.8	5/3/2017	20:12	< 2.0		2	1 Y	ND
HES-1-1A-CF-P	N	2224670002	ALS	NJ PA010	4/20/2017	5:01	EPA 200.8	5/3/2017	20:20	7.7		2	1 Y	
HES-1-16-DW-P	N	2224670003	ALS	NJ PA010	4/20/2017	5:02	EPA 200.8	5/3/2017	20:23	421		2	1 Y	
HES-1-16-CF-P	N	2224670004	ALS	NJ PA010	4/20/2017	5:03	EPA 200.8	5/3/2017	20:26	6.8		2	1 Y	
HES-1-15-SB-P	N	2224670005	ALS	NJ PA010	4/20/2017	5:04	EPA 200.8	5/3/2017	20:28	3.1		2	1 Y	
HES-1-15-CF-P	N	2224670006	ALS	NJ PA010	4/20/2017	5:05	EPA 200.8	5/3/2017	20:31	3.4		2	1 Y	
HES-1-2-CF-P	N	2224670007	ALS	NJ PA010	4/20/2017	5:06	EPA 200.8	5/3/2017	20:34	3.8		2	1 Y	
HES-1-14-SB-P	N	2224670008	ALS	NJ PA010	4/20/2017	5:08	EPA 200.8	5/3/2017	20:36	2.4		2	1 Y	
HES-1-14-CF-P	N	2224670009	ALS	NJ PA010	4/20/2017	5:09	EPA 200.8	5/3/2017	20:39	2.7		2	1 Y	
HES-1-3-SB-P	N	2224670010	ALS	NJ PA010	4/20/2017	5:11	EPA 200.8	5/3/2017	20:42	< 2.0		2	1 Y	ND
HES-1-3-CF-P	N	2224670011	ALS	NJ PA010	4/20/2017	5:12	EPA 200.8	5/3/2017	20:55	< 2.0		2	1 Y	ND
HES-1-13-SB-P	N	2224670012	ALS	NJ PA010	4/20/2017	5:13	EPA 200.8	5/3/2017	20:58	3.5		2	1 Y	
HES-1-13-CF-P	N	2224670013	ALS	NJ PA010	4/20/2017	5:14	EPA 200.8	5/3/2017	21:01	2.5		2	1 Y	
HES-1-4-SB-P	N	2224670014	ALS	NJ PA010	4/20/2017	5:16	EPA 200.8	5/3/2017	21:03	3.3		2	1 Y	
HES-1-4-CF-P	N	2224670015	ALS	NJ PA010	4/20/2017	5:17	EPA 200.8	5/3/2017	21:06	3.8		2	1 Y	
HES-1-12-SB-P	N	2224670016	ALS	NJ PA010	4/20/2017	5:18	EPA 200.8	5/3/2017	21:09	4.3		2	1 Y	
HES-1-12-CF-P	N	2224670017	ALS	NJ PA010	4/20/2017	5:19	EPA 200.8	5/3/2017	21:11	4		2	1 Y	
HES-1-11-SB-P	N	2224670018	ALS	NJ PA010	4/20/2017	5:20	EPA 200.8	5/3/2017	21:14	< 2.0		2	1 Y	ND
HES-1-11-CF-P	N	2224670019	ALS	NJ PA010	4/20/2017	5:21	EPA 200.8	5/3/2017	21:17	2.1		2	1 Y	
HES-1-5-SB-P	N	2224670020	ALS	NJ PA010	4/20/2017	5:22	EPA 200.8	5/3/2017	21:25	2.6		2	1 Y	
HES-1-5-CF-P	N	2224670021	ALS	NJ PA010	4/20/2017	5:23	EPA 200.8	5/3/2017	21:33	3.7		2	1 Y	
HES-1-10-SB-P	N	2224670022	ALS	NJ PA010	4/20/2017	5:24	EPA 200.8	5/3/2017	21:36	2.4		2	1 Y	
HES-1-10-CF-P	N	2224670023	ALS	NJ PA010	4/20/2017	5:25	EPA 200.8	5/3/2017	21:38	3.5		2	1 Y	
HES-1-6-SB-P	N	2224670024	ALS	NJ PA010	4/20/2017	5:26	EPA 200.8	5/3/2017	21:41	2.3		2	1 Y	
HES-1-6-CF-P	N	2224670025	ALS	NJ PA010	4/20/2017	5:27	EPA 200.8	5/3/2017	21:44	< 2.0		2	1 Y	ND
HES-1-H9A-DW-P	N	2224670026	ALS	NJ PA010	4/20/2017	5:28	EPA 200.8	5/3/2017	21:46	14.1		2	1 Y	
HES-1-8-CF-P	N	2224670027	ALS	NJ PA010	4/20/2017	5:30	EPA 200.8	5/3/2017	21:49	4		2	1 Y	
HES-1-H7-DW-P	N	2224670028	ALS	NJ PA010	4/20/2017	5:31	EPA 200.8	5/3/2017	21:57	10.3		2	1 Y	
HES-1-7-CF-P	N	2224670029	ALS	NJ PA010	4/20/2017	5:34	EPA 200.8	5/3/2017	22:00	< 2.0		2	1 Y	ND
HES-1-HLIB-WC1-P	N	2224670030	ALS	NJ PA010	4/20/2017	5:37	EPA 200.8	5/3/2017	22:03	< 2.0		2	1 Y	ND
HES-1-HLIB-WC2-P	N	2224670031	ALS	NJ PA010	4/20/2017	5:38	EPA 200.8	5/3/2017	22:11	< 2.0		2	1 Y	ND
HES-1-Library-TF-P	N	2224670032	ALS	NJ PA010	4/20/2017	5:39	EPA 200.8	5/3/2017	22:13	5.5		2	1 Y	
HES-1-Kitchen-FP-P	N	2224670033	ALS	NJ PA010	4/20/2017	5:41	EPA 200.8	5/3/2017	22:16	4.1		2	1 Y	
HES-1-TR-TF-P	N	2224670034	ALS	NJ PA010	4/20/2017	5:42	EPA 200.8	5/3/2017	22:19	8.4		2	1 Y	
HES-1-Nurse-NS1-P	N	2224670035	ALS	NJ PA010	4/20/2017	5:44	EPA 200.8	5/3/2017	22:21	< 2.0		2	1 Y	ND
HES-1-Nurse-NS2-P	N	2224670036	ALS	NJ PA010	4/20/2017	5:45	EPA 200.8	5/3/2017	22:30	< 2.0		2	1 Y	ND
HES-1-MO-TF-P	N	2224670037	ALS	NJ PA010	4/20/2017	5:46	EPA 200.8	5/3/2017	22:32	< 2.0		2	1 Y	ND
HES-1-Entrance-DW-FN	N	2224670038	ALS	NJ PA010	4/20/2017	5:47	EPA 200.8	5/3/2017	22:35	2.7		2	1 Y	
HES-1-H114-DW-P	N	2224670039	ALS	NJ PA010	4/20/2017	5:49	EPA 200.8	5/3/2017	22:38	9.4		2	1 Y	
HES-1-CST-CF-P	N	2224670040	ALS	NJ PA010	4/20/2017	5:50	EPA 200.8	5/3/2017	22:40	< 2.0		2	1 Y	ND
HES-1-HGYM-DW-P	N	2224670041	ALS	NJ PA010	4/20/2017	5:51	EPA 200.8	5/3/2017	22:48	4.7		2	1 Y	
HES-1-101-CF-P	N	2224670042	ALS	NJ PA010	4/20/2017	5:52	EPA 200.8	5/3/2017	22:51	16.9		2	1 Y	
HES-1-102-CF-P	N	2224670043	ALS	NJ PA010	4/20/2017	5:53	EPA 200.8	5/3/2017	22:54	27		2	1 Y	
HES-1-102-DW-P	N	2224670044	ALS	NJ PA010	4/20/2017	5:54	EPA 200.8	5/3/2017	23:02	9.1		2	1 Y	
HES-1-103-CF-P	N	2224670045	ALS	NJ PA010	4/20/2017	5:55	EPA 200.8	5/3/2017	23:05	15.9		2	1 Y	
HES-1-103-DW-P	N	2224670046	ALS	NJ PA010	4/20/2017	5:56	EPA 200.8	5/3/2017	23:07	4.5		2	1 Y	
HES-1-104-DW-P	N	2224670047	ALS	NJ PA010	4/20/2017	5:57	EPA 200.8	5/3/2017	23:10	17.8		2	1 Y	
HES-1-104-CF-P	N	2224670048	ALS	NJ PA010	4/20/2017	5:58	EPA 200.8	5/3/2017	23:13	6.9		2	1 Y	
HES-1-113-SB-P	N	2224670049	ALS	NJ PA010	4/20/2017	5:59	EPA 200.8	5/3/2017	23:15	9.6		2	1 Y	
HES-1-113-CF-P	N	2224670050	ALS	NJ PA010	4/20/2017	6:00	EPA 200.8	5/3/2017	23:18	15.4		2	1 Y	
HES-1-105-SB-P	N	2224670051	ALS	NJ PA010	4/20/2017	6:02	EPA 200.8	5/3/2017	23:26	7.1		2	1 Y	
HES-1-105-CF-P	N	2224670052	ALS	NJ PA010	4/20/2017	6:03	EPA 200.8	5/3/2017	23:34	7.4		2	1 Y	
HES-1-112-DW-P	N	2224670053	ALS	NJ PA010	4/20/2017	6:04	EPA 200.8	5/3/2017	23:37	33.6		2	1 Y	
HES-1-112-CF-P	N	2224670054	ALS	NJ PA010	4/20/2017	6:05	EPA 200.8	5/3/2017	23:40	142		2	1 Y	
HES-1-106-DW-P	N	2224670055	ALS	NJ PA010	4/20/2017	6:06	EPA 200.8	5/3/2017	23:42	5.7		2	1 Y	
HES-1-106-CF-P	N	2224670056	ALS	NJ PA010	4/20/2017	6:07	EPA 200.8	5/3/2017	23:45	4.1		2	1 Y	
HES-1-111-DW-P	N	2224670057	ALS	NJ PA010	4/20/2017	6:08	EPA 200.8	5/2/2017	12:15	94.1		1	1 Y	
HES-1-111-CF-P	N	2224670058	ALS	NJ PA010	4/20/2017	6:09	EPA 200.8	5/3/2017	23:48	33.2		2	1 Y	
HES-1-107-CF-P	N	2224670059	ALS	NJ PA010	4/20/2017	6:11	EPA 200.8	5/3/2017	23:50	14.6		2	1 Y	
HES-1-110-DW-P	N	2224670060	ALS	NJ PA010	4/20/2017	6:13	EPA 200.8	5/3/2017	23:53	37.6		2	1 Y	
HES-1-110-CF-P	N	2224670061	ALS	NJ PA010	4/20/2017	6:14	EPA 200.8	5/3/2017	23:56	13.6		2	1 Y	
HES-1-108-DW-P	N	2224670062	ALS	NJ PA010	4/20/2017	6:15	EPA 200.8	5/4/2017	0:09	6		2	1 Y	
HES-1-108-CF-P	N	2224670063	ALS	NJ PA010	4/20/2017	6:16	EPA 200.8	5/4/2017	0:12	23.1		2	1 Y	
HES-1-109-SB-P	N	2224670064	ALS	NJ PA010	4/20/2017	6:17	EPA 200.8	5/4/2017	0:15	10.3		2	1 Y	
HES-1-109-CF-P	N	2224670065	ALS	NJ PA010	4/20/2017	6:18	EPA 200.8	5/4/2017	0:17	7.7		2	1 Y	

Close to EPA Action Limit (>15.5)ppb

Exceeds EPA Action Limit ( > 15.5ppb)

Bldg ID - Room / Location ID / Floor - Outlet Type - (P)rimary / (F)lush / Number in Sequence

OUTLET TYPE

BF = Bathroom Faucet

CF = Classroom Faucet  
DW = Drinking Water Fountain  
FP = Food Prep  
HS = Hand Sink  
IM = Ice Machine  
KC = Kitchen Outlet, Cold  
KT= Kettle  
SS = Slop Sink  
TF = Teachers Faucet  
WC = Water Cooler